CRYOGENIC PRESSURE CALIBRATION FACILITY USING A COLD FORCE REFERENCE

T. Bager, J. Casas and L. Metral

Abstract

Presently various commercial cryogenic pressure sensors are being investigated for installation in the LHC collider, they will eventually be used to assess that the magnets are fully immersed in liquid and to monitor fast pressure transients.

In the framework of this selection procedure, a cryogenic pressure calibration facility has been designed and built. It is based on a cryogenic primary pressure reference made of a bellows that converts the pressure into a force measurement. For that, a shaft transfers this force to a precision force transducer at room temperature. Knowing the liquid bath pressure and the surface area of the bellows, the pressure applied to the transducers under calibration is calculated; corrections due to thermal contraction are introduced. To avoid loss of force in the bellows wall, its length is maintained constant; a cold capacitive displacement sensor measures this. The calibration temperature covers 1.5 K to 4.2 K and the pressure 0 to 20 bar. In contrast with more classical techniques that refer to a pressure reference at room temperature, the method presented in this paper avoids errors due to the uncertainty on the hydrostatic head calculation, to thermoacoustic oscillations and to pressure variation caused by temperature drift along the sensing capillary.

LHC Division

Presented at the 1999 Cryogenic Engineering and International Cryogenic Materials Conference
(CEC-ICMC'99), 12-16 July 1999, Montreal, Canada

Administrative Secretariat
LHC Division
CERN
CH - 1211 Geneva 23
Switzerland

Geneva, 1 December 1999

CRYOGENIC PRESSURE CALIBRATION FACILITY USING A COLD FORCE REFERENCE

T. Bager, J. Casas and L. Metral

LHC Division
CERN, European Organization for Nuclear Research
1211 Geneva 23, Switzerland

ABSTRACT

Presently various commercial cryogenic pressure sensors are being investigated for installation in the LHC collider, they will eventually be used to assess that the magnets are fully immersed in liquid and to monitor fast pressure transients.

In the framework of this selection procedure, a cryogenic pressure calibration facility has been designed and built. It is based on a cryogenic primary pressure reference made of a bellows that converts the pressure into a force measurement. For that, a shaft transfers this force to a precision force transducer at room temperature. Knowing the liquid bath pressure and the surface area of the bellows, the pressure applied to the transducers under calibration is calculated; corrections due to thermal contraction are introduced. To avoid loss of force in the bellows wall, its length is maintained constant; a cold capacitive displacement sensor measures this. The calibration temperature covers 1.5 K to 4.2 K and the pressure 0 to 20 bar. In contrast with more classical techniques that refer to a pressure reference at room temperature, the method presented in this paper avoids errors due to the uncertainty on the hydrostatic head calculation, to thermoacoustic oscillations and to pressure variation caused by temperature drift along the sensing capillary.

INTRODUCTION

The test setup is shown in Figure 1.

Cryostat

The cryostat has two liquid helium (LHe) reservoirs in the same vacuum vessel. The outer reservoir is shaped like a cylindrical shell, it is continuously filled with LHe at 4.2 K and acts as a thermal screen for the inner one. A cryogenic valve (18) is used for filling the inner reservoir.

The inner reservoir dimensions are $\varnothing 30$ cm x 1 m, a high capacity primary pump (8) regulates its saturated LHe temperature between 1.5 and 4.2 K. The saturation pressure is measured with a high accuracy pressure sensor (7).

Figure 1. Schematic view of the cryostat

Pressurised test volume

A gaseous helium (GHe) cylinder at 20 MPa is connected to a pressure regulator (1) resulting in a variable test pressure of 0.1 – 2 MPa. Sub-atmospheric pressures are obtained by means of a primary vacuum pump (3). A capillary (10) is used as hydraulic connection between the warm and cold parts of the experiment and its pressure is always monitored by a high accuracy warm pressure reference (2). The capillary is wound into a helical heat exchanger (16) to cool the helium entering the test volume, which can be isolated by a cryogenic shut-off valve (17).

The distribution flange (15) is made of two 316L stainless steel (SS) disks welded together and it is attached to the main flange (9) by metallic tubes (12). Threaded holes are

machined in the distribution flange allowing the installation of cryogenic pressure sensors. A bellows (13) is used to convert the inner pressure into a force that is measured with a warm force transducer (6). Risk of buckling imposes a minimum value to the bellows stiffness. The bellows length is measured with a capacitive sensor (14) and it is maintained constant by a linear actuator (5).

MECHANICAL CONSIDERATIONS

Pressure-to-force conversion

The bellows is made of electrodeposited nickel (Ni) and has two 316L SS end caps. The effective end cap surface area and the bellows inner and outer pressure determine the force transferred through the shaft (11) that by design is limited to about 1060 N.

The effective surface area is measured in warm conditions and thermal contraction effects are taken into account when operating in cryogenic conditions. With liquid helium the correction factor for effective surface area is:

$$\frac{A_{316L, 4K}}{A_{316L, 293K}} = \left(1 - \int_{4K}^{293K} dl/l\right)^2 = (1 - 3.31 \times 10^{-3})^2 \quad (1)$$

$$= 0.9934$$

Alignment

A critical source of uncertainty is the alignment of shaft, bellows and force transducer. The bellows end-cap is aligned by design with the shaft (11), a transversal displacement of 0.35 mm of the shaft end-cap position is observed when varying the bellows inner pressure from vacuum to 2 MPa. This corresponds to an angular variation of about 0.021° that results in a negligible correction. At cryogenic temperatures it is assumed lower due to higher stiffness.

Torque is minimised since shaft (11) and bellows assembly (13) are not attached to each other by a fixed connection. At low force the bellows is almost free to rotate without transferring torque to the load cell. No shaft rotation is observed during pressurising at 293 K.

Elastic deformation

Ideally the bellows length should be maintained constant because its finite stiffness is a source of uncertainty. However elastic deformations are unavoidable and their effects should be investigated and compensated if necessary in the load cell, the shaft, the support tubes and the actuator support.

The shaft and support tubes are made of respectively one and three 316L SS tubes. The actuator support consists of three tubes, two are made of 316L SS and one of aluminium.

The elastic compression/expansion is calculated by:

$$\Delta L = \frac{L \times F}{A \times E} \quad (2)$$

where ΔL is the elastic expansion, A the effective cross section area, F the force and E the modulus of elasticity. Table 1 shows the results for each critical component, a load cell expansion of 108 μm is deduced from manufacturer data.

Table 1. Mechanical characteristics of force transmission components.

	Shaft	Support tubes	Actuator support 1	Actuator support 2	Actuator support 3
Force	1058 N	1058 N	1058 N	1058 N	1058 N
Tube length	970 mm	810 mm	100 mm	100 mm	100 mm
Tube cross section	Ø28x1	3 *(Ø16x0.5)	Ø70x2	Ø100x2	Ø70x3
Worst case modulus	195 GPa	195 GPa	195 GPa	195 GPa	70 GPa
Calculated max elastic expansion of tubes at full load	62 µm	60 µm	1.3 µm	0.9 µm	3.5 µm

Thermal deformations

Thermal contraction is also a source of uncertainty and the main contributors are the support tubes, the shaft (both made of SS) and the bellows. A first approximation is to calculate the thermal contraction difference of Ni and 316L over the bellows length of 13.9 mm.

$$\Delta L_{316L} = \int_{4K}^{293K} dl/l \times L = 3.31 \times 10^{-3} \times 13.9 = 46 \mu m \quad (3)$$

$$\Delta L_{Ni} = \int_{4K}^{293K} dl/l \times L = 2.30 \times 10^{-3} \times 13.9 = 32 \mu m \quad (4)$$

$$\Delta L_{thermal} = \Delta L_{316L} - \Delta L_{Ni} = 14 \mu m \quad (5)$$

Overall deformation

The total deflection of the construction is due to the additive effects of elastic and thermal deformation:

$$\Delta L_{total} = \Delta L_{thermal} + \Delta L_{elastic} = 249 \mu m \quad (6)$$

Without any compensation, such variation in the bellows length would result in part of the force being taken by the stiffness of the bellows wall. At room temperature this force can be estimated by using manufacturer data:

$$F_{bellows\ wall, 293K} = springrate_{bellows, 293K} \times \Delta L_{total} = 11 N \quad (7)$$

This effect might result in an uncertainty of 1%. At cryogenic temperatures the bellows stiffness is higher and it is difficult to implement a compensation algorithm. In consequence a capacitive displacement sensor and a linear actuator are used to maintain the bellows length constant to within $\pm 5 \mu m$. When operating in LHe, the displacement sensor output should be corrected by approximately 5% as shown in Table 2.

Table 2. Relative dielectric constant in various relevant media

Media	Relative dielectric constant
air, 300 K	1.0005
LHe, 4.2 K	1.049
LHe, 1.8 K	1.057

OPERATION PRINCIPLE

Setting the initial bellows position

Since the bellows is not attached mechanically to the shaft, it is operated with a slight pre-compression, and the applied force through the shaft is always oriented in the same direction independently of the operating temperature. The compression of the bellows is obtained by manipulating the linear displacement actuator while monitoring the force transducer. With a Δp of 0.1 MPa, a springrate of 45 N/mm² and an area of 529 mm², the minimal required pre-compression is as a first approximation:

$$\text{Bellows compression}_{\max} = \frac{\Delta p \times A_{\text{bellows}}}{\text{springrate}_{\text{bellows}}} = 1.2 \text{ mm} \quad (8)$$

By taking a safety margin of about 20 % the actual pre-compression is 1.4 mm, thus the resulting compression force is 9 N, thus reducing the force transducer dynamic range by 0.08 %.

Bellows effective area

The bellows effective surface area for converting pressure into force is determined at room temperature. In this case the warm pressure reference is used and the cryogenic shut-off valve is open. A set of measurements is taken and the best linear fit between measured pressure and force (Figure 2) is used for determining the effective surface area; the repeatability of these measurements is better than 0.15 %. Corrections are used to take into account thermal contraction.

Operation at cryogenic temperatures

When calibrating a set of cryogenic sensors the pressurized volume is gradually filled with gaseous helium until a given pressure setpoint (measured by the warm pressure reference) is reached. During the filling, the bellows length is monitored by the capacitive sensor and is maintained constant by means of the linear displacement actuator. The cryogenic shut-off valve is then closed and a combined measure of the force transducer, inner cryostat pressure and LHe level of the inner reservoir is done. The pressurized helium temperature is measured by using a resistance thermometer calibrated between 1.6 K and 300 K. Pressure sensors under test are energized according to manufacturers recommendations (usually 10 V_{DC}) and their outputs recorded.

The applied pressure is calculated by:

$$p_{\text{sensor}} = \frac{F_{LC}}{A_{\text{bellows area}}} + p_{\text{inner cryostat}} + p_{\text{liquid head}} \quad (9)$$

The liquid level head contributes with a pressure of (see Table 3):

$$p_{\text{liquid head}} = L_{LHe} \times g \times \rho_{LHe} \quad (10)$$

Table 3. Pressure formed by liquid head

P _{liquid head}	L = 10 cm	L = 40 cm
T = 4.2 K	0.12 kPa	0.49 kPa
T = 1.8 K	0.14 kPa	0.57 kPa

Figure 2. Calculation of bellows area

The pressure inside the test volume is varied from vacuum to the maximum range of the pressure sensors or 2 MPa, whatever is lower. A measurement in vacuum conditions permits elimination of bellows effects due to the pre-compression and to the dependence with temperature of bellows stiffness.

Sensors under test are located 10 cm lower than bellows, thus for pressures above saturation pressure the liquid head inside the pressurised chamber is 0.12/0.14 kPa, which must be added to sensor pressure. For pressures below saturation pressure the hydrostatic head consists of gas only and is below 16 Pa.

Apparatus

A MacIntoshTM computer running LabVIEWTM is used for control and data acquisition. IEEE-488 is used for communication between the computer and the instruments. A digital multi-meter with an integrated 20-channel scanner is used for monitoring the temperatures and other diagnostic instruments. The pressure reference is directly read through the bus.

All the LHC-prototype pressure sensors have a membrane for separating a reference vacuum chamber from the pressurized media. The displacement of the membrane is a function of the applied pressure. Depending on the sensor, this displacement is measured by strain gauges, reluctance coils or optical techniques.

For strain gauges an HBMTM ML10 amplifier was used. This instrument is used for measuring the force transducer and up to 5 pressure sensors simultaneously. The excitation voltage is typically 10 V_{DC} and the accuracy is 0.03 % of full scale.

For reluctance coils and optical type pressure sensors, a specific instrument for conditioning the output is supplied by the sensor manufacturer. In such cases it is not

Table 4. Combined errors of instruments.

Bellows area	Pressure inner cryostat	Force measurement	Liquid head	Bellows position	Conditioner for sensors under test
0.17 %	0.29 kPa (~145 ppm)	0.12 % FS	29 Pa (~15 ppm)	20 nm	300 ppm FS

possible to discriminate whether the uncertainties come from the electronic unit or the sensor itself.

The pressure inside the capillary is measured by a MensorTM 2106 warm pressure reference with a range of 0 to 2.6 MPa and an uncertainty of 0.65 kPa. The liquid helium level is measured by using a superconducting probe with an uncertainty of about 2 cm. The inner reservoir pressure is measured by an industrial pressure transducer and the HBMTM amplifier, the uncertainty is 0.29 kPa.

The linear displacement actuator is programmed via RS232 by a computer and controlled during operation by a keypad. The maximal displacement is 20 mm, the resolution better than 1 μm and has backlash of about 12 μm . This actuator is used regularly during cool-down and warm-up requiring displacement of up to 200 μm .

Instrument errors are summarised in Table 4.

EXPERIMENTAL RESULTS

Operation at 4.2 K

Preliminary tests have been performed at 4.2 K and four different types of pressure sensors have been tested. A relatively good linearity between sensor output and applied pressure is observed. The deviation from best straight line is for all sensors less than 3 kPa ($\sim 0.15\%$ FS). See Figure 3. A short overview of sensor types tested can be found in Table 5.

The accuracy obtained has been limited by a leak in the cryogenic shut-off valve that result in oscillations and drift in the force transducer. The seal of this valve will be changed and we expect its leak-tightness not to be a limiting factor in the ultimate uncertainty that can be obtained with this calibration facility.

Figure 3. Sensors under test, deviation from best straight line

Table 5. Main characteristics of sensors tested

	Sensor 1	Sensor 2	Sensor 3	Sensor 4
Diaphragm	metal (w 1.4542)	metal (15.5PH)	SiO ₂	Metal (Inconel)
Sensing principle	Strain gauge metallic resistance	Strain gauge metallic resistance	Strain gauge metallic resistance	Inductive, brass target
Excitation	10 V _{DC} , 5 k Ω	10 V _{DC} , 1.25 k Ω	10 V _{DC} , 0.7 k Ω	56 kHz AC
Nominal output @FS	20 mV	30 mV	28 mV	4-20 mA (1)

Note (1) : Output of dedicated signal conditioner

CONCLUSION

A facility for calibrating cryogenic pressure sensors has been fabricated and commissioned. It is based in a primary cryogenic pressure reference made of a bellows and a piston transmitting the resulting force into a high-accuracy force transducer, in order to eliminate uncertainties related to an unknown pressure head inside the sensing capillary. The pressurized volume can be isolated from the capillary strongly reducing the effects of pressure oscillations that can be observed with the warm pressure reference.

ACKNOWLEDGMENT

Thanks for good ideas to Ph. Lebrun, CERN, for manufacturing components to P. Portier and J. Beltron, CERN, for help on operating to P. Romand, CERN.

REFERENCES

- H.E.Krex. "Maskinståbi", Teknisk Forlag, København (1986).
J.G. Weisend II. "Handbook of Cryogenic Engineering", Taylor & Francis, Philadelphia (1998).
Hepak Software, Cryodata Inc., Niwot, Co (1993).